

# LENORA WATER AND SEWER DISTRICT (LWSD)

## PROPOSAL SOLICITATION

FOR

SUPPLY/DELIVERY

OF

## WATER SYSTEM SERVICE METER AND WATER DISTRIBUTION SYSTEM MATERIALS

Reference attached Materials Schedule of Values and Specifications.

Your Company is invited to submit a proposal to supply water service and water system distribution system pipe, valves and fittings.

Proposal Requirements:

1. Written Proposals shall be accepted until 5 PM, November 4, 2015.
2. Proposals shall be submitted electronically to: [lenorawaterandsewer@gmail.com](mailto:lenorawaterandsewer@gmail.com) with copy to [bartdnorth@frontier.com](mailto:bartdnorth@frontier.com) and [mikec@skookumlightingdesign.com](mailto:mikec@skookumlightingdesign.com).
3. Proposals may be submitted in Company's format provided the quantity, unit price, price extension, price sub-total, and total quote amount (with 7.6% Washington State Sales Tax) are submitted in a legible format.
4. Proposal shall provide a schedule for a single delivery of the materials requested by this solicitation.

Evaluation of Proposal

1. Award shall be made to the lowest responsive Bidder.
2. LWSD shall have the right to reject any or all bids.
3. Upon award to the lowest Bidder, Bidder shall provide a Contract Agreement for Owner Signature.

LWSD is an equal opportunity and affirmative action employer. Disadvantaged Business Enterprises (small, minority- and women-owned businesses) are encouraged to submit proposals. No labor requiring Washington State Prevailing or Davis Bacon Wages are anticipated for the supply/delivery of the water service and distribution system materials requested by this solicitation.

This project is funded by a federal loan from the Department of Health, Public Works Board and Department of Commerce Drinking Water State Revolving Loan fund program.

LWSD WATER SERVICE AND DISTRIBUTION PIPE/VALVE/FITTING PROPOSAL SOLICITATION  
 SCHEDULE OF VALUES FOR MATERIALS QUOTE  
 10/19/2015

ITEM	DESCRIPTION	UNIT	QTY	UNIT PRICE	TOTAL
<b>WATER METERS</b>					
1	5/8"x3/4" Meter	EA	82		
2	METER BOX - LID	EA	82		
3	METER BOX - TOP SECTION	EA	82		
4	METER BOX - MIDDLE SECTION	EA	160		
5	3/4" PEP X METER SWIVEL ANGLE BALL METER VALVE	EA	82		
6	3/4" PEP X METER SWIVEL ANGLE SINGLE CHECK VALVE	EA	82		
7	3/4" SDR 7 CL 200 POLY	LF	1600		
8	3/4" IPS STIFFENER	EA	320		
9	3/4" MNPT FROST PROOF YARD HYDRANT (5'BURY)	EA	50		
10	3/4" BRASS FNPT 90 ELBOW	EA	164		
11	3/4" X 12" SCH 40 BRASS NIPPLE	EA	82		
<b>WATER SERVICES</b>					
12	3/4" PEP X FIPT CURB STOP	EA	40		
13	3/4" X 12" SCH 40 BRASS NIPPLE	EA	120		
14	3/4" FNPT TEE	EA	10		
15	3/4" PEP X FNPT ADAPTOR	EA	80		
16	3/4" PEP X PEP ADAPTOR	EA	80		
17	3/4" IPS STIFFENER	EA	80		
18	3/4" SDR 7 CL 200 POLY	LF	800		
19	4" ASTM 3034 PVC RISER PIPE	LF	200		
20	6" SLP CAP	EA	40		
<b>ISOLATION VALVES</b>					
21	1 1/2" FNPT X PVC PACK JOINT CURB STOP	EA	15		
22	2" FNPT X PVC PACK JOINT CURB STOP	EA	1		
23	1 1/2" X 12" SCH 40 BRASS NIPPLE	EA	15		
24	2" X 12" SCH 40 BRASS NIPPLE	EA	1		
25	4" ASTM 3034 PVC RISER PIPE	LF	60		
26	6" SLP CAP	EA	16		
<b>2" FLUSH HYDRANT (3 EACH)</b>					
27	2" FNPT PACK JOINT CURB STOP	EA	3		
28	2"X 48" SCH 40 BRASS NIPPLE	EA	3		
29	2"X 6" SCH 40 BRASS NIPPLE	EA	6		
30	2" BRASS FIPT COUPLER	EA	3		
31	2" MIPT PLUG	EA	3		
32	4" ASTM 3034 PVC RISER PIPE	LF	30		
33	6" SLP CAP	EA	6		
<b>MISC</b>					
34	CURB STOP VALVE KEY	EA	2		
35	3/4" SCH 40 PVC COMPRESSION COUPLER	EA	10		
36	1 1/2" SCH 40 PVC COMPRESSION COUPLER	EA	10		
37	2" SCH 40 PVC COMPRESSION COUPLER	EA	10		
				<b>SUB-TOTAL</b>	
				<b>7.6% WSST:</b>	
				<b>TOTAL QUOTE PRICE:</b>	

**NOTES:**

- 1 - MATERIALS SUBSTITUTIONS MAY BE ALLOWED WITH WRITTEN PRE-QUALIFICATION AS "OR EQUAL" BY LWSD
- 2 - ALL MATERIALS SHALL CONFIRM TO NSF 61, BE LEAD FREE, AND CONFORM TO ALL APPLICABLE REGULATION PERTAINING TO POTABLE WATER SERVICE AS APPLICABLE
- 3 - PRICE SHALL INCLUDE DELIVERY OF ALL MATERIALS TO 1091 LENORA DRIVE, USK WA, 99180

LWSD WATER SERVICE AND DISTRIBUTION PIPE/VALVE/FITTING PROPOSAL SOLICITATION  
MATERIALS SPECIFICATIONS  
10/19/2015

ITEM	DESCRIPTION	MANUFACTURER
<b>WATER METERS</b>		
1	5/8"x3/4" Meter	DIRECT READ GALLONS: MASTER METER MULTI-JET, BADGER, M25 ENVIRO, OR PRE-APPROVED EQUAL
2	METER BOX - COVER	CARSON BCF 1324 HD PLASTIC WITH READER DOOR, 12" SECTION
3	METER BOX - TOP SECTION	CARSON BCF 1324, 12" SECTION
4	METER BOX - MIDDLE SECTION	CARSON BCF 1324, 12" SECTION
5	3/4" PEP X METER SWIVEL ANGLE BALL METER VALVE	FORD, A.Y. MCDONALD
6	3/4" PEP X METER SWIVEL ANGLE SINGLE CHECK VALVE	FORD, A.Y. MCDONALD
7	3/4" SDR 7 CL 200 POLY	(NONE SPECIFIED)
8	3/4" IPS STIFFENER	FORD, A.Y. MCDONALD
9	3/4" MNPT FROST PROOF YARD HYDRANT (5'BURY)	SIMMONS 4805LF - 5 FT BURY
10	3/4" BRASS FNPT 90 ELBOW	FORD, A.Y. MCDONALD
11	3/4" X 12" SCH 40 BRASS NIPPLE	FORD, A.Y. MCDONALD
<b>WATER SERVICES</b>		
12	3/4" PEP X FIPT CURB STOP	FORD, A.Y. MCDONALD
13	3/4" X 12" SCH 40 BRASS NIPPLE	FORD, A.Y. MCDONALD
14	3/4" FNPT TEE	FORD, A.Y. MCDONALD
15	3/4" PEP X FNPT ADAPTOR	FORD, A.Y. MCDONALD
16	3/4" PEP X PEP ADAPTOR	FORD, A.Y. MCDONALD
17	3/4" IPS STIFFENER	FORD, A.Y. MCDONALD
18	3/4" SDR 7 CL 200 POLY	(NONE SPECIFIED)
19	4" ASTM 3034 PVC RISER PIPE	(NONE SPECIFIED)
20	6" SLP CAP	(NONE SPECIFIED)
<b>ISOLATION VALVES</b>		
21	1 1/2" FNPT X PVC PACK JOINT CURB STOP	FORD, A.Y. MCDONALD
22	2" FNPT X PVC PACK JOINT CURB STOP	FORD, A.Y. MCDONALD
23	1 1/2" X 12" SCH 40 BRASS NIPPLE	FORD, A.Y. MCDONALD
24	2" X 12" SCH 40 BRASS NIPPLE	FORD, A.Y. MCDONALD
25	4" ASTM 3034 PVC RISER PIPE	(NONE SPECIFIED)
26	6" SLP CAP	(NONE SPECIFIED)
<b>2" FLUSH HYDRANT (3 EACH)</b>		
27	2" FNPT PACK JOINT CURB STOP	FORD, A.Y. MCDONALD
28	2"X 48" SCH 40 BRASS NIPPLE	FORD, A.Y. MCDONALD
29	2"X 6" SCH 40 BRASS NIPPLE	FORD, A.Y. MCDONALD
30	2" BRASS FIPT COUPLER	FORD, A.Y. MCDONALD
31	2" MIPT PLUG	FORD, A.Y. MCDONALD
32	4" ASTM 3034 PVC RISER PIPE	(NONE SPECIFIED)
33	6" SLP CAP	(NONE SPECIFIED)
<b>MISC</b>		
34	CURB STOP VALVE KEY	FORD, A.Y. MCDONALD
35	3/4" SCH 40 PVC COMPRESSION COUPLER	(NONE SPECIFIED)
36	1 1/2" SCH 40 PVC COMPRESSION COUPLER	(NONE SPECIFIED)
37	2" SCH 40 PVC COMPRESSION COUPLER	(NONE SPECIFIED)

**NOTES:**

- 1 - MATERIALS SUBSTITUTIONS MAY BE ALLOWED WITH WRITTEN PRE-QUALIFICATION AS "OR EQUAL" BY LWSD
- 2 - ALL MATERIALS SHALL CONFIRM TO NSF 61, BE LEAD FREE, AND CONFORM TO ALL APPLICABLE REGULATION PERTAINING TO POTABLE WATER SERVICE AS APPLICABLE
- 3 - PRICE SHALL INCLUDE DELIVERY OF ALL MATERIALS TO 1091 LENORA DRIVE, USK WA, 99180