

**ADDENDUM NO. 1**

To the Contract Provisions for  
CITY OF ZILLAH, WASHINGTON

**VINTAGE VALLEY LIFT STATION  
IMPROVEMENTS**

HLA Project No. 15160

**BID OPENING: May 24, 2016**

**11:00 a.m.**

To the attention of all bidders for the above project:

The following additions, revisions, and/or modifications are made to the Contract Documents, Plans, and Specifications for this project:

**SECTION 6 – TECHNICAL SPECIFICATION CHANGES**

SECTION 26 43 00 – TRANSIENT VOLTAGE SUPPRESSION

1. Revise paragraph 2.2 C. to read "...120kA per phase, 60kA per mode." in lieu of "...240kA per phase, 120kA per mode."
2. Delete paragraph 3.2 B.

**CONTRACT PLAN CHANGES**

SHEET 10 OF 11


1. Revise Note 11 to add the following sentence: "Coordinate termination connector at each end with equipment to be connected and terminate with required connector."

SHEET 11 OF 11

1. Revise Note 2 to indicate the existing generator connection is model number AP20034CDRS in lieu of AP20034DCRS.
2. Revise the Elevation Electrical Equipment Rack to show the anchor plates bedded in a layer of bitumastic between the grout pad and the metal foot plate.

This ADDENDUM is to be considered as much a part of the contract provisions as if it were included in the body of the Plans and Specifications.

All Bidders shall acknowledge receipt of the ADDENDUM on the proposal form prior to bid opening.

  
Justin L. Bellamy, PE  
HLA Engineering and Land Surveying, Inc.  
2803 River Road  
Yakima, WA 98902  
Phone: (509) 966-7000

Date

5/18/2016